

Installation Instructions

EV-LEDFIRE-III-SM 1689 FV-I FDFIRF-III-SM-B 1690



CODE: 1689



CODE:1690

CONTENTS

- Welcome
- 2. Overview
- Safety warnings
- 4. Installation
- 5. Mounting options
- 6. Terminal block wiring
- 7. Maintaining your SM Ledfire III luminaire
- Replacing the battery
- Battery life
- 10. Power and battery charge
- 11. Wireless daughterboard
- 12. Self-test/ standard wiring/ central battery system
- 13. DALI wiring/ central battery system
- 14. Using the inverter with a switch
- 15. Using the inverter with a sensor
- Accessories list
- 17. Non maintained/ maintained jumper
- 18. Discharge rating selection
- 19. Self-test indicator LEDs
- 20. Self-test/ commissioning interval programming
- 21. Product specifications
- 22. Australian emergency classification
- 23. Spacing table
- 24. Construction sites
- 25. Testing precautions
- 26. Problem solving procedure
- 27. Warranty information
- 28. Compliance standards
- 29. Technical support and troubleshooting

I. WELCOME

Thank you for choosing this quality Ektor product. This manual is intended to help you install this product in a way that ensures the safety of yourself and others. Whilst this Ektor product is designed to be installed easily, we highly recommend you take the time to read this manual thoroughly before commencing installation. When installed correctly and serviced regularly, this product will provide hassle free operation for many years.









2. OVERVIEW

Ektor Generation III platform introduces you to a new era of emergency lighting control. With years in the making, the third generation platform builds on the Ektor product ranges' increasing quality, reliability and performance. In choosing this Ektor product you can be comfortable that you have the best.

Out of the box this product can be wired in any of these configurations:

- Self-testing unit
- Standalone unit
- Standalone unit controlled with a switch or sensor
- DALI controlled remote testing unit

And can be used with a central battery system (monitored and non-monitored)

An optional wireless module can be added to allow you to connect to standard Wi-Fi networks for remote testing and reporting.

Our Ektor Generation III platform also brings class leading technology which increases performance and reliability including:

- Smart battery charging technology which reduces power consumption up to 90% while increasing the service life of the battery
- Smart battery conditioning to ensure the best performance from the battery
- 450V Electrolytic capacitors which increase the products reliability
- Highly efficient design to reduce fatigue on the product

For buildings requiring longer durations such as 3, 4 and 8 hours the installer can change the jumpers found on the unit for automatic scaling of the output. Moreover should you require non-maintained or maintained output, the installer can select this on installation.

3. SAFETY WARNINGS

- I. THIS PRODUCT MUST ONLY BE INSTALLED BY A LICENSED ELECTRICIAN.
- 2. BEFORE COMMENCING INSTALLATION TURN OFF AND ISOLATE THE ELECTRICAL SUPPLY.
- 3. DO NOT ENERGISE WITH PRODUCT OPEN OR DISASSEMBLED.
- 4. SUPPLY VOLTAGES WITHIN PRODUCT. ISOLATE SUPPLY VOLTAGES BEFORE OPENING OR SERVICING.
- 5. THE ONLY USER SERVICEABLE PART IS THE BATTERY PACK.
- 6. DO NOT ATTEMPT TO SERVICE OTHER PARTS OF THE FITTING AS THIS WILL VOID THE WARRANTY.
- 7. AS THE INSTALLER, IT IS YOUR RESPONSIBILITY TO ENSURE YOU COMPLY TO ALL RELEVANT BUILDING AND SAFETY CODES FOR EXAMPLE THE BCA, AS3000. REFER TO APPLICATION STANDARDS FOR THE RELEVANT RULES.
- 8. WHEN THE INSTALLATION IS COMPLETE, LEAVE THIS MANUAL WITH THE BUILDING'S OWNER/S FOR FUTURE REFERENCE.

4. INSTALLATION

The Ektor Surface Mount Ledfire III can be installed either by surface or rod mounting the product. To install the Surface Mount Ledfire III please follow the steps listed below:

- Remove the product from the box and inspect it for any damage. If you believe the product to be damaged or otherwise unsound, DO NOT install the product. Please pack it back into its box and return it to the place of purchase for replacement. If the product is satisfactory, proceed with the installation.
- 2. When mounting the Surface Mount Ledfire III the cover MUST be removed. Remove the cover using a flat blade screwdriver to release the clips and pull the cover upwards as shown below.
- **3.** The cover must also be removed for battery replacement and servicing. All installation options can be found in the following section of this manual.




Figure 1: Surface Mount Ledfire III disassembly and installation

5. MOUNTING OPTIONS

SURFACE MOUNT

- 1. Remove the Surface Mount Ledfire III cover as shown in the installation instructions in section 4 (page 3) of this instruction manual. This will allow the mounting holes to become visible.
- **2.** Mount the Surface Mount Ledfire III by fastening screws securely to a flat surface.





Figure 2: Surface mount installation

ROD MOUNT

Refer to installation guide (EV-RODMOUNT) included in the rod mount kit. The product and rod MUST BE dry and clean before assembly to avoid joint contamination.

- 1. Disassemble the Surface Mount Ledfire III as shown in the installation instructions in section 4 (page 3) of this manual. This will allow for the rod mount to be assembled to the products top cover.
- 2. Ensure rod is mounted ONLY on a flat surface and fasten with the appropriate fixing e.g. masonry anchor for concrete.
- **3.** A \emptyset 25 tube is to be used, pushed firmly in on both ends and fastened.



NOTE: DO NOT overtighten screws when mounting the rod mount to the Surface Mount Ledfire III.

The rod mount is suitable with tubes ranging from 0-2 metres in length. The weight on the rod must not exceed 8kg.

Figure 3: Rod mount installation

6. TERMINAL BLOCK WIRING

Wiring schematic for the terminal block used with the Surface Mount Ledfire III is illustrated below.




Figure 4: Wiring schematic

7. MAINTAINING YOUR SM LEDIRE III LUMINAIRE

⚠ WARNING

The Surface Mount Ledfire III is connected to an unswitched active during normal operating conditions. When disconnected from the mains supply, the Surface Mount Ledfire III is powered by a LiFePO4 battery operated inverter. Due to this, care should be taken when replacing the battery.

8. REPLACING THE BATTERY

- 1. Use only the LiFePO4 battery recommended on the label found on the inverter/battery charger pack. No other battery will work in this fitting, other than the type listed.
- 2. Access the battery by removing the product cover as shown in section 4 (page 3) of this manual.
- **3.** Disconnect the battery from the product and if necessary, cut cable ties to release the battery from its mounting position.
- **4.** Replace the battery as was previously installed and then reinstall inverter/battery pack or install as per all relevant standard requirements.
- **5.** Replace the Surface Mount Ledfire III back into its previously mounted ceiling position and ensure the green charge light is illuminated. Allow a few minutes for the battery to charge.
- **6.** Allow a minimum 24 hours charging time before carrying out any discharge tests as per the requirements in AS/NZS 2293. BCA or other relevant standards.



Figure 5: Example of included battery

9. BATTERY LIFE

The economic life of the battery installed in this unit is 4 years; it is recommended that the battery is replaced after this time. To maintain the economic life of this product it is required that the battery be discharged and recharged at least once every 6 months. The battery life can be reduced if the battery is not discharged as per the requirements of AS/NZS 2293 or an equivalent standard. Increasing the number of duration tests above that as defined in AS/NZS 2293 or an equivalent standard can have a positive effect on the battery performance as long as 12 discharge cycles per year is not exceeded.

10. POWER AND BATTERY CHARGE

The Ektor Generation III platform uses smart battery charging technology which reduces power consumption and increases battery life.




Figure 6: Smart charge rate

During the first stage of operation the battery charger charges the battery until full. Afterwards, the unit goes into a stage which charges the battery periodically. This reduces the battery temperature and reduces the loss of electrolytes which ultimately increases the service life of the battery.

The smart battery charger also offsets the charging time by a random interval to un-synchronise all the emergency lighting in the building. This reduces the average loading on a building's infrastructure and reduces any impacts of surges created by turning on large numbers of products simultaneously.

II. WIRELESS DAGHTERBOARD

The Surface Mount Ledfire III inverter supports an optional wireless daughterboard. The driver must be disconnected from mains and battery must be removed, before installing or changing any expansion module. More information and a list of other accessories can be found in the **Wireless design and installation guide**. The assembly for the Wireless daughterboard onto the inverter is shown below:




Figure 7: Daughterboard assembly diagram

12. SELF-TEST/ STANDARD WIRING/ CENTRAL BATTERY SYSTEM




Figure 8: Inverter standard wiring diagram

The inverter can be used in an automatic self-test mode which reduces the need for a test switch timer. The self-test ability automatically disables if the unit is wired to DALI or the wireless daughterboard is attached. Additionally the third generation platform can be wired to a central battery system. With this wiring the system cannot report the light status (see **Self-test support** document for more information).

13. DALI WIRING/ CENTRAL BATTERY SYSTEM

The Surface Mount Ledfire III inverter supports DALI out of the box, illustrated in the hardwiring diagram shown below. The inverter also supports central battery systems and can be monitored through DALI. When used as a central battery system the devices can be tested with DALI.




Figure 9: Inverter DALI wiring diagram

14. USING THE INVERTER WITH A SWITCH

A mains rated switch can be wired with this product to turn ON/OFF the non-emergency light in normal use. This does not affect operation in emergency mode.




Figure 10: Inverter switch wiring diagram

15. USING THE INVERTER WITH A SENSOR

A mains rated sensor can be wired with this product to turn ON/OFF the light in normal use. This does not affect operation in emergency mode.




Figure 11: Inverter sensor wiring diagram

16. ACCESSORIES LIST

Below are the listings of the accessories and replacements compatible with the Surface Mount Ledfire III.

EV-LEDFIRE-III-SM	1689
EV-LEDFIRE-III-SM-B	1690
EV-LEDFIRE-III-SM-INV	1204
EV-3000mAh-6.4V-LiFePO4	1303
EV-WIFI-DAUG	6118
EV-ECM-DALI	5304
EV-ECM-EKTOR	5305
	EV-LEDFIRE-III-SM-B EV-LEDFIRE-III-SM-INV EV-3000mAh-6.4V-LiFePO4 EV-WIFI-DAUG EV-ECM-DALI

17. NON MAINTAINED/ MAINTAINED JUMPER

A user can select the mode of operation for the Surface Mount Ledfire III inverter. If the inverter is using a switch input this is disregarded and not used.

INDICATOR	STATUS	DESCRIPTION
NON MAINTAINED		LED is only ON in emergency
MAINTAINED MODE		LED is ON in normal and emergency operation




Figure 12: Maintained/non-maintained jumper

18. DISCHARGE RATING SELECTION

The inverter supports a number of discharge ratings which can be selected by the user. The output from the LED scales based on the discharge rating (see section 22 for output classification information).

I hour OFF OFF OFF OFF OFF OFF OFF ON ON ON ON ON OFF ON OFF ON ON OFF ON ON OFF ON OFF ON OFF ON ON OFF ON O	HOURS	А	В	C		
	2 hours (default) 3 hours 4 hours 8 hours Central battery operation	ON ON ON ON	ON ON OFF OFF ON	ON OFF ON OFF	Remove expansion cover	

Figure 13: Discharge rating selection

19. SELF-TEST INDICATOR LEDS


The table below shows the operation of the Surface Mount Ledfire III status indicators:

INDICATOR	DESCRIPTION
¥¥YELLOW 2sec ON / 2sec OFF	Device is performing a duration test
YELLOW 4sec ON / Isec OFF	Last duration test passed. The duration was met when last run. Test ran less than five days ago
YELLOW 0.5sec ON / 0.5sec OFF	Last duration test failed. Failed to meet duration. The device is not currently running a new test. Mains is on
∰: GREEN IxFlash	A duration test is pending. The device is not in any self-test and set to normal mode

20. SELF-TEST/ COMMISSIONING INTERVAL PROGRAMMING


The self-test mode must first be enabled to perform tests. This is done by switching the breaker in the correct sequence as illustrated below. The same sequence can also be used with the test button on a single device.

The test interval is fixed and set to 26 weeks / 182 days. The LEDs indicate the status of the device and which functions are being performed. For more information refer to the **Configurations: Status LEDs and Device Modes** document.



21. PRODUCT SPECIFICATIONS

SURFACE MOUNT LEDFIRE III



2 -	0		
/ -	()	Im	m

Voltage (V)	230~240V	Viewing distance	N/A
Frequency (Hz)	50Hz	Mounting type	Surface mounted
Max. ambient temp.	40°C	Wiring	Hard wired
Battery type	LiFePO4		
Class	2	Battery voltage	6.4V
Duration	Dependant on jumper	Charging time	16 hours
IP rating	IP20	Charger operation	Multi state
Storage temperature	0-50°C	Charger type	Smart charge

SURFACE MOUNT LEDFIRE III

7 Watts Max. power

NOTE: Maximum power consumption in the following configuration: 230VAC 50Hz, I hour discharge, maintained mode, charging active.

22. AUSTRALIAN EMERGENCY CLASSIFICATION

Classification of the Surface Mount Ledfire III output when duration is selected.

HOURS	SURFACE MOUNT LEDFIRE III
I	D63
2	D63
3	D32
4	D25
8	D8

23. SPACING TABLE

Below is the spacing table extract from AS/NZS 2293 which details spacing between emergency fittings at different mounting heights.

LUMINAIRE					MOl	JNTING	HEIGHT	(M)								
CLASSIFICATION	2.1	2.4	2.7	3	3.3	3.6	4	4.5	5	6	7	8	9	10	15	20
D8	9.4	9.7	9.9	10.1	10.2	10.3	10.4	10.3	10.2	9.5	8.3	6.1				
D25	14.2	14.7	15.3	15.7	16.1	16.5	16.9	17.3	17.7	18.1	18.3	18.2	17.9	17.3	7.7	
D32	15.4	16.1	16.7	17.2	17.6	18.0	18.5	19.1	19.5	20.2	20.6	20.7	20.6	20.3	14.6	
D63	19.4	20.3	21.1	21.8	22.4	23.0	23.7	24.5	25.2	26.4	27.4	28.1	28.6	28.9	28.0	22.5

24. CONSTRUCTION SITES

IMPORTANT NOTE: Continuously switching the power supply to the fitting on and off during or after the installation process due to other processes being conducted on the building site could cause the fitting to discharge and charge its battery many times during a short period which can impact negatively on the battery life. It is not recommended that you connect the Ektor emergency products to the power supply if such conditions are prevalent. If you choose to expose the Ektor emergency products to such harsh operating conditions, Evolt may not honour any warranty on the life of the batteries or the product enclosure. This Ektor emergency product is designed to undergo regular discharge tests but it is recommended that the intervals between consecutive tests are not less than two weeks. Frequent testing of the exit product will reduce the service life of the battery. In order to prevent damage to the battery, leave the unswitched active circuit turned off at the circuit breaker until such time as emergency lighting is required

25. TESTING PRECAUTIONS

When the Ektor emergency product is permanently connected to the mains supply you will need to allow the battery to have 24 hours to charge. Once the battery is fully charged you will need to conduct a manual discharge test as per the requirements of AS/NZS 2293 or other relevant standards. At the time of printing, the Australian standard requires that new fittings operate in emergency mode for at least 2 hours for their first discharge test. Further tests are to be carried out at intervals of not more than six months. It is important that you keep records of the initial test and ongoing tests in the building's emergency service logbook. If the fitting is not to be permanently connected to the mains supply at the time of installation, you must give it the mandatory 2 hour test when you connect it permanently to the mains supply.

26. PROBLEM SOLVING PROCEDURE

If you have installed and connected the Ektor Surface Mount Ledfire III as per the instructions contained within this manual and the product fails to work properly, please use the following table as a guide to fixing the problem before calling our office.

FAULT	POSSIBLE CAUSES
Green LED is not lit	 AC supply is not connected AC supply turned off Battery plug not connected to battery pack
Green LED is lit but the lamp does not light when the test switch is pressed	Lamp is damagedLamp is not inserted properlyBattery pack is damaged
Lamp lights, but only temporarily, when test switch is pressed or when the main power supply is turned off	Battery pack not fully charged Battery pack is damaged

27. WARRANTY INFORMATION

Ektor products are distributed in Australia and New Zealand by Evolt Pty Ltd (Evolt).

The Australian Consumer Law as well as other Australian laws guarantee certain conditions, warranties and undertakings, and give you other legal rights, in relation to the quality and fitness for purpose of Ektor products sold in Australia.

In Australia, our goods come with guarantees that cannot be excluded under the Australian Consumer Law. You are entitled to a replacement or refund for a major failure and compensation for any other reasonably foreseeable loss or damage. You are also entitled to have the goods repaired or replaced if the goods fail to be of acceptable quality and the failure does not amount to a major failure. What constitutes a major failure is set out in the Australian Consumer Law.

Nothing in this Warranty purports to modify or exclude the conditions, warranties and undertakings, and other legal rights, under the Australian Competition and Consumer Act and other Australian laws. Ektor products are warranted in Australia for a period of 12 months from the date of delivery of the product, provided that the products are properly stored, installed, used and maintained in accordance with the instructions contained within their manual.

Products that have been altered in any way or used other than in accordance with their instructions are not covered by this warranty.

This warranty is not transferrable and is valid only in the hands of the purchaser of the product. The warranty does not cover Ektor products other than those purchased from Evolt. Proof of purchase must be provided to Evolt with any warranty claim. Evolt recommends that the purchaser attaches their proof of purchase to their product manual.

Evolt's total liability under this warranty is limited to the cost of repair or replacement of the faulty product. Evolt may satisfy its obligations under this warranty in full by repair or replacement of a faulty product. This warranty does not apply to consumable items such as lamps or batteries or other items that can be classified as consumable.

For the avoidance of any doubt, any and all warranties or conditions which are not guaranteed under the Australian Competition and Consumer Act or the Australian Competition and Consumer Regulations 2010 and which are not expressly included in this Warranty as additional warranties or conditions are excluded.

This Warranty does not cover loss or damage caused by wear and tear, misuse, incorrect installation or operation, failure to clean and maintain, incorrect voltage or non-authorised electrical connections, adverse external conditions (such as power surges and dips, acts of God, exposure to heat, corrosion, insect or vermin infestation), use of non-authorised or defective parts or globes, or to items that have been repaired other than by Evolt or a repairer approved by Evolt.

28. COMPLIANCE STANDARDS

	STANDARD	TITLE
Australian/ New Zealand Standards	AS/NZS 2293-3:2005+A1:2010	Emergency escape lighting and exit signs for buildings. Part 3: Emergency escape luminaires and exit signs.
	AS/NZS 60598-2-22:2005	Luminaires Part 2.22: Particular requirements - Luminaires for emergency lighting (IEC 60598-2-22, Ed. 3.1 (2002) MOD).
	AS 61000.3.2:2007 + AI:2009	Electromagnetic compatibility (EMC) - Limits - Limits for harmonic current emissions (equipment input current (16 A per phase) (IEC 61000-3-2, Ed.3.0 (2005) MOD).
	AS/NZS CISPR 15:2011	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment.
European Committee for Standardisation	EN 60598-1:2008+A11:2009	Luminaires - Part 1: General requirements and tests.
	EN 60598-2-22:1998+A1:2003+A2:2008	Luminaires - Part 2-22: Particular requirements - Luminaires for emergency lighting.
	EN 55015:2006+A1:2007+A2:2009	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment.
	EN 61547:2009	Equipment for general lighting purposes - Electromagnetic compatibility (EMC) immunity requirements.
	EN 61000-3-2:2006+A1:2009+A2:2009	Electromagnetic compatibility (EMC) Limits. Limits for harmonic current emissions (equipment input current ≤ 16 A per phase).
	EN 61000-3-3: 2008	Electromagnetic compatibility (EMC) - Part 3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current <= 16 A per phase and not subject to conditional connection.

29. TECHNICAL SUPPORT AND TROUBLESHOOTING

For further assistance in using this product, consult your nearest wholesaler or Evolt Pty Ltd. Be aware that illustrations and images used are for illustration purposes only and, changes may apply to products after the release of this document.

Ph: + 612 9502 1161 Fax: + 612 9502 1154 Email: sales@evolt.com.au

evolt.com.au

Reference: 602893_V2

