

MANUFACTURER'S DECLARATION OF CONFORMITY

<i>No.</i>	EX.073-2012
<i>Issuer's name:</i>	GEWISS S.p.A.
<i>Issuer's address:</i>	Via A. Volta, 1 24069 Cenate Sotto (BG) ITALY
<i>Object of the declaration:</i>	Square acces chamber – PZ Range Mechanical Strength Type References: DX59401; DX59701; DX59801; DX59901 and DX59501

We declare that the products mentioned above underwent the following standard test:

<i>Standard No.(Edition) & Title</i>	<i>Required Test</i>
EN 124: 1994 Gully tops and manhole tops for vehicular and pedestrian areas - Design requirements, type testing, marking, quality control.	PAR. 8.1 - MECHANICAL STRENGTH

With the following severities and results:

Type reference	Dimensions	Test punch	Breaking load
DX59401	200x200x200	∅ 75 mm	325 kg (7,4 kg/cm ²)
DX59701	300x300x300	∅ 150 mm	850 kg (4,8 kg/cm ²)
DX59801	400x400x400	∅ 250 mm	980 kg (2,0 kg/cm ²)
DX59901	550x550x520	∅ 250 mm	1325 kg (2,7 kg/cm ²)
DX59501	360x260x326	∅ 150 mm	1360 kg (7,7 kg/cm ²)

Signed for and on behalf of: GEWISS S.p.A.

Place and Date: Cenate Sotto, 23rd August 2012

MATTEO GAVAZZENI.....
Standards, Quality Marks & Patents Manager

